



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-159-13**

Valid from: 2025 04 27
until: 2027 04 27

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Portable socket-outlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 39539**

Österreichischer Verband für Elektrotechnik

T. Neumayer
Head of OVE Certification
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at



Wien, 2025 03 26

Dipl.-Ing. T. Neumayer

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
OVE EN IEC 60309-1:2023-07-01
OVE EN IEC 60309-2:2023-07-01
IEC 60309-1:2021
IEC 60309-2:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Portable socket-outlets for industrial purposes

Type designation:

Rating:

Trademark:

262

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
without minor key

PCE / ELCEE / METECEE

282

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
with minor key

PCE / ELCEE / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

263

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
without minor key

PCE / ELCEE / METECEE

283

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
with minor key

PCE / ELCEE / METECEE

2622

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
without minor key

PCE / ELCEE / METECEE

2822

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
with minor key

PCE / ELCEE / METECEE

2632

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
without minor key

PCE / ELCEE / METECEE

2832

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
with minor key

PCE / ELCEE / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Type code:

2	8	3	2	-	12	v	
							contacts
							blank uncoated contacts
							v nickel plated contacts
							colour
							blank indicating colour
							* reserved for additional colours
							clock position earthing contact
							blank without minor keyway
							2 2 h
							3 3 h
							4 4 h
							10 10 h (only 2-poles)
							11 11 h
							12 12 h
							minor keyway / costumer type
							blank without minor keyway / PCE
							- with minor keyway / PCE
							degree of protection
							blank IP44 or IP44/IP54
							2 IP67 or IP66/IP67
							poles
							2 2-poles
							3 3-poles
							rated current / minor keyway
							6 16 A / without minor keyway
							8 16 A / with minor keyway
							ground type
							2 portable socket outlet

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Poles	I [A]	[h]	Degree of protection	Rated operating voltage [V]	Frequency [Hz]	Insulation voltage [V]
262	2	16	-	IP44 or IP44/IP54	20 - 25	50 and 60	50
282			12		40 - 50	50 and 60	
			4		20 - 25 and 40 - 50	100 - 200	
			2			300	
			3			400	
			11			> 400 - 500	
			10			DC	
263	3	16	-	20 - 25	50 and 60	50	
283			12	40 - 50	50 and 60		
			4	20 - 25 and 40 - 50	100 - 200		
			2		300		
			3		400		
			11		> 400 - 500		
			10		DC		
2622	2	16	-	20 - 25	50 and 60	50	
2822			12	40 - 50	50 and 60		
			4	20 - 25 and 40 - 50	100 - 200		
			2		300		
			3		400		
			11		> 400 - 500		
			10		DC		
2632	3	16	-	20 - 25	50 and 60	50	
2832			12	40 - 50	50 and 60		
			4	20 - 25 and 40 - 50	100 - 200		
			2		300		
			3		400		
			11		> 400 - 500		
			10		DC		

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.