



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-163-15**

Valid from: 2025 04 19
until: 2027 04 19

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Switched socket-outlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **3704-1858/22**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2025 03 19



OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
ÖVE/ÖNORM EN 60309-4:2012-12-01
OVE EN IEC 60309-1:2023-07-01
OVE EN IEC 60309-2:2023-07-01
OVE EN IEC 60309-4:2023-04-01
IEC 60309-1:2021
IEC 60309-2:2021
IEC 60309-4:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Switched socket-outlets for industrial purposes

Type designation:

Rating:

Trademark:

6023

Rated current: 32 A
IP44 or IP44/IP54
2P+PE

PCE / ELCEE / IDE

6123

Rated current: 32 A
IP44 or IP44/IP54
2P+PE

PCE / ELCEE / IDE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

6024

Rated current: 32 A
IP44 or IP44/IP54
3P+PE

PCE / ELCEE / IDE

6124

Rated current: 32 A
IP44 or IP44/IP54
3P+PE

PCE / ELCEE / IDE

6025

Rated current: 32 A
IP44 or IP44/IP54
3P+N+PE

PCE / ELCEE / IDE

6125

Rated current: 32 A
IP44 or IP44/IP54
3P+N+PE

PCE / ELCEE / IDE

60232

Rated current: 32 A
IP67 or IP66/IP67
2P+PE

PCE / ELCEE / IDE

61232

Rated current: 32 A
IP67 or IP66/IP67
2P+PE

PCE / ELCEE / IDE

60242

Rated current: 32 A
IP67 or IP66/IP67
3P+PE

PCE / ELCEE / IDE

61242

Rated current: 32 A
IP67 or IP66/IP67
3P+PE

PCE / ELCEE / IDE

60252

Rated current: 32 A
IP67 or IP66/IP67
3P+N+PE

PCE / ELCEE / IDE

61252

Rated current: 32 A
IP67 or IP66/IP67
3P+N+PE

PCE / ELCEE / IDE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Type code

60	2	3	2	-	6	*	*	*
----	---	---	---	---	---	---	---	---

Housing

blank	Without knock-outs
k	With knock-outs

Contacts

blank	Nickel plated contacts
b	Uncoated contacts

Colour

blank	Indicating colour
xs	Midnight-series
*	Reserved for additional colours

Clock position earthing contact

1	1 h
3	3 h
4	4 h
5	5 h
6	6 h
7	7 h (not available for 3-poles)
9	9 h
11	11 h
12	12 h

Customer type

-	Trademark PCE
---	---------------

Degree of protection

blank	IP44 or IP44/IP54
2	IP67 or IP66/IP67

Poles

3	3-poles
4	4-poles
5	5-poles

Rated current

2	32 A
---	------

Ground type

60	Panel-type switched socket outlet
61	Surface-type switched socket outlet

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
6023 6123 60232 61232	32	1	Other ratings	Other ratings	690
		4	100 – 130	50 and 60	690
		6	200 – 250	50 and 60	690
		9	380 – 415	50 and 60	690
		12	Supply from an isolating transformer	50 and 60	690
6024 6124 60242 61242	32	1	Other ratings	Other ratings	690
		3	380 440	50 60	690
		4	100 – 130	50 and 60	690
		5	600 – 690	50 and 60	690
		6	380 – 415	50 and 60	690
		7	480 - 500	50 and 60	690
		9	200 – 250	50 and 60	690
		11	440 – 460	60	690
		12	Supply from an isolating transformer	50 and 60	690
6025 6125 60252 61252	32	1	Other ratings	Other ratings	690
		3	220/380 250/440	50 60	690
		4	57/100 – 75/130	50 and 60	690
		5	347/600 – 400/690	50 and 60	690
		6	200/346 – 240/415	50 and 60	690
		7	277/480 – 288/500	50 and 60	690
		9	120/208 – 144/250	50 and 60	690
		11	250/440 – 265/460	60	690
		12	Supply from an isolating transformer	50 and 60	690

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.