



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-167-17**

Valid from: 2025 07 07
until: 2027 07 07

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Appliance inlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **3722-1862/23**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2025 07 02



OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
OVE EN IEC 60309-1:2023-07-01
OVE EN IEC 60309-2:2023-07-01
IEC 60309-1:2021
IEC 60309-2:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Appliance inlets for industrial purposes

Type designation:

Rating:

Trademark:

533

Rated supply current: 63 A
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

633

Rated supply current: 63 A
2P+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

733

Rated supply current: 63 A
2P+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

77733

Rated supply current: 63 A
2P+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

534

Rated supply current: 63 A
3P+PE
IP 67 or IP 66/IP 67
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

634

Rated supply current: 63 A
3P+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

734

Rated supply current: 63 A
3P+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

77734

Rated supply current: 63 A
3P+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

535

Rated supply current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

635

Rated supply current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

735

Rated supply current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

77735

Rated supply current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

5332

Rated supply current: 63 A
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

6332

Rated supply current: 63 A
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

7332

Rated supply current: 63 A
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

777332

Rated supply current: 63 A
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

5342

Rated supply current: 63 A
3P+PE
IP 67 or IP 66/IP 67
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

6342

Rated supply current: 63 A
3P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

7342

Rated supply current: 63 A
3P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

777342

Rated supply current: 63 A
3P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

5352

Rated supply current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

6352

Rated supply current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

7352

Rated supply current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

777352

Rated supply current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

5331

Rated supply current: 63 A
2P+PE
IP 44
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

53321

Rated supply current: 63 A
2P+PE
IP 44
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

5341

Rated supply current: 63 A
3P+PE
IP 44
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

53421

Rated supply current: 63 A
3P+PE
IP 44
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

5351

Rated supply current: 63 A
3P+N+PE
IP 44
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

53521

Rated supply current: 63 A

3P+N+PE

IP 44

without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

6331

Rated supply current: 63 A

2P+PE

IP 44

with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

63321

Rated supply current: 63 A

2P+PE

IP 44

without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

6341

Rated supply current: 63 A

3P+PE

IP 44

with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

63421

Rated supply current: 63 A

3P+PE

IP 44

without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

6351

Rated supply current: 63 A

3P+N+PE

IP 44

with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

63521

Rated supply current: 63 A

3P+N+PE

IP 44

without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

777331

Rated supply current: 63 A

2P+PE

IP 44

with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

7773321

Rated supply current: 63 A

2P+PE

IP 44

without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

777341

Rated supply current: 63 A

3P+PE

IP 44

with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

7773421

Rated supply current: 63 A

3P+PE

IP 44

without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

777351

Rated supply current: 63 A

3P+N+PE

IP 44

with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

7773521

Rated supply current: 63 A

3P+N+PE

IP 44

without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

777	3	5	2	1	-	6	k	*	b
-----	---	---	---	---	---	---	---	---	---

Contacts

blank	nickel plated contacts
b	uncoated contacts

Colour

blank	standard type
xs	Midnight series
*	reserved for additional colours

Specification

blank	standard type
k	version with compact housing (for types of series 6 and 777)

Clock position earthing contact

1	1 h
2	2 h
3	3 h
4	4 h
5	5 h
6	6 h
7	7 h
8	8 h (not available in 4- and 5-poles)
9	9 h
10	10 h
11	11 h
12	12 h

Customer type

-	Trademark PCE
---	---------------

Degree of protection

blank	IP67 or IP66/IP67
1	IP44

Pilot contact

blank	with pilot contact
2	without pilot contact

Poles

3	3-poles
4	4-poles
5	5-poles

Rated current

3	63A
---	-----

Ground type

777	Flanged plug
5	Wall mounted plug
6	Flanged plug straight
7	Flanged plug sloping

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
533 633 733 77733 5332 6332 7332 777332	63	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	>50 - 250	DC	690
		4	100 - 130	50 and 60	690
		6	200 - 250	50 and 60	690
		7	480 - 500	50 and 60	690
		8	>250	DC	690
		9	380 - 415	50 and 60	690
		10	>50	>100 - 300	690
		12	Supply from an isolating transformer	50 and 60	690
534 634 734 77734 5342 6342 7342 777342	63	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	380 440	50 60	690
		4	100 - 130	50 and 60	690
		5	600 - 690	50 and 60	690
		6	380 - 415	50 and 60	690
		7	480 - 500	50 and 60	690
		9	200 - 250	50 and 60	690
		10	>50	>100 - 300	690
		11	440 - 460	60	690
		12	Supply from an isolating transformer	50 and 60	690
535 635 735 77735 5352 6352 7352 777352	63	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	220/380 250/440	50 60	690
		4	57/100 - 75/130	50 and 60	690
		5	347/600 - 400/690	50 and 60	690
		6	200/346 - 240/415	50 and 60	690
		7	277/480 - 288/500	50 and 60	690
		9	120/208 - 144/250	50 and 60	690
		10	>50	>100 - 300	690
		11	250/440 - 265/460	60	690
		12	Supply from an isolating transformer	50 and 60	690

OVE Certification


Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
5331 6331 777331 53321 63321 7773321	63	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	>50 - 250	DC	690
		4	100 - 130	50 and 60	690
		6	200 - 250	50 and 60	690
		7	480 - 500	50 and 60	690
		8	>250	DC	690
		9	380 - 415	50 and 60	690
		10	>50	>100 - 300	690
5341 6341 777341 53421 63421 7773421	63	12	Supply from an isolating transformer	50 and 60	690
		1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	380 440	50 60	690
		4	100 - 130	50 and 60	690
		5	600 - 690	50 and 60	690
		6	380 - 415	50 and 60	690
		7	480 - 500	50 and 60	690
		9	200 - 250	50 and 60	690
5351 6351 777351 53521 63521 7773521	63	10	>50	>100 - 300	690
		11	440 - 460	60	690
		12	Supply from an isolating transformer	50 and 60	690
		1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	220/380 250/440	50 60	690
		4	57/100 - 75/130	50 and 60	690
		5	347/600 - 400/690	50 and 60	690
		6	200/346 - 240/415	50 and 60	690
	63	7	277/480 - 288/500	50 and 60	690
		9	120/208 - 144/250	50 and 60	690
		10	>50	>100 - 300	690
		11	250/440 - 265/460	60	690
		12	Supply from an isolating transformer	50 and 60	690

Accessories:

ts7632 •



OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.