



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-132-16**

Valid from: 2025 07 09
until: 2027 07 09

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Two-pole plug with side earthing contacts or dual earthing system**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 39848**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2025 08 21



OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

OVE E 8684-1:2019-12-01
OVE E 8684-1:2021-12-01
OVE E 8684-1/A1:2025-04-01
IEC 60884-1:2022
DIN VDE 0620-1 (VDE 0620-1):2021-02

Product: Two-pole plug with side earthing contacts or dual earthing system

Type designation:

Rating:

Trademark:

05..

Rated supply voltage: AC 250 V
Rated supply current: 16 A
IP 54
see typecode

PCE / ELCEE

056..

Rated supply voltage: AC 250 V
Rated supply current: 16 A
IP 44
see typecode

PCE / ELCEE

058..

Rated supply voltage: AC 250 V
Rated supply current: 16 A
IP 44
see typecode

PCE / ELCEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typecode

05	6	1	1	-	s	r
----	---	---	---	---	---	---

Colour hexagonal ring (only Types 051* and 052*)

r	red
he	yellow
s	black
o	orange
b	Blue
hb	lightblue
u	green RAL 6031 F9
hu	fluorescent green
su	siemensgreen
g	grey
dg	darkgrey
w	white
a	anthracite
*	reserved for different colours

Colour housing part

s	black
e	yellow
r	red
o	orange
b	blue
u	green
g	grey
a	anthracite
*	reserved for different colours

Costumer type

-	PCE
---	-----

Contact carrier

1	PA6 lightgrey (internal cord anchorage) black (external cord anchorage)
2	TPE (anthracite)
3	PA6 black (internal cord anchorage)

Standardsheet

1	S.S. IV (with side earthing contacts)
2	S.S.VII (Two-pole plug)

Basic type

blank	with internal cord anchorage (IP54)
6	with external cord anchorage (IP44)
8	angled plug (IP44)

Plug

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.